


# Certificate of Conformity

Certificate Number: CN-PVES-200092R1

On the basis of the tests undertaken, the samples of the below product have been found to comply with the requirements of the referenced specifications /standards at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture. The manufacturer shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

Applicant Name & Address:	Shenzhen Growatt New Energy Co., Ltd 4-13/F, Building A, Sino-German (Europe) Industrial Park, Hangcheng Ave, Bao'an District, Shenzhen, China
Product Description:	PV Grid inverter
Ratings & Principle	See Annex to Certificate of Conformity
Characteristics:	
Models/Type References:	MOD 3000TL3-X, MOD 4000TL3-X, MOD 5000TL3-X, MOD 6000TL3-X, MOD 7000TL3-X, MOD 8000TL3-X, MOD 9000TL3-X, MOD 10KTL3-X, MOD 11KTL3-X, MOD 12KTL3-X, MOD 13KTL3-X, MOD 15KTL3-X MOD 3000TL3-X2(Pro), MOD 4000TL3-X2(Pro), MOD 5000TL3-X2(Pro), MOD 6000TL3-X2(Pro), MOD 7000TL3-X2(Pro), MOD 8000TL3-X2(Pro), MOD 9000TL3-X2(Pro), MOD 10KTL3-X2(Pro), MOD 11KTL3-X2(Pro), MOD 12KTL3-X2(Pro), MOD 13KTL3-X2(Pro), MOD 15KTL3-X2(Pro)
Brand Name:	GROWATT
Specification/Standard:	IEC 61727:2004 Photovoltaic (PV) systems – Characteristics of the utility interface IEC 62116:2014 Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters
Certificate Issuing Office Name & Address:	Intertek Testing Services Ltd. Shanghai West Area, 2 <sup>nd</sup> Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012
Test Report Number:	240105052GZU-001, 28 April 2024 240105052GZU-002, 28 April 2024

Replaces Certificate No. CN-PV-200092, dated 22 July 2020  
Additional information in Appendix.



Signature

**Certification Manager: Grady Ye**  
**Date: 29 April 2024**



PRD N° 306B

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-200092R1

Model	MOD 3000TL3-X	MOD 4000TL3-X	MOD 5000TL3-X	MOD 6000TL3-X
Max. PV voltage	1100Vdc			
PV voltage range	140 – 1000Vdc			
PV Isc	2*16A			
Max. input current	2*13A			
Max. output power	3000W	4000W	5000W	6000W
Max. apparent power	3300VA	4400VA	5500VA	6600VA
Nominal output voltage	3W/N/PE 230/400Vac			
Max. output current	5.0A	6.7A	8.3A	10.0A
Nominal output frequency	50/60Hz			
Power factor range	0.8Leading ~ 0.8Lagging			
Safety level	Class I			
Ingress protection	IP66			
Operation ambient temperature	-25°C - +60°C			
Software version	DL 1.0			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-200092R1

Model	MOD 7000TL3-X	MOD 8000TL3-X	MOD 9000TL3-X	MOD 10KTL3-X
Max. PV voltage	1100Vdc			
PV voltage range	140 – 1000Vdc			
PV Isc	2*16A			
Max. input current	2*13A			
Max. output power	7000W	8000W	9000W	10000W
Max. apparent power	7700VA	8800VA	9900VA	11000VA
Nominal output voltage	3W/N/PE 230/400Vac			
Max. output current	11.7A	13.3A	15.0A	16.7A
Nominal output frequency	50/60Hz			
Power factor range	0.8Leading ~ 0.8Lagging			
Safety level	Class I			
Ingress protection	IP66			
Operation ambient temperature	-25°C - +60°C			
Software version	DL 1.0			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-200092R1

Model	MOD 11KTL3-X	MOD 12KTL3-X	MOD 13KTL3-X	MOD 15KTL3-X
Max. PV voltage	1100Vdc			
PV voltage range	140 – 1000Vdc			
PV Isc	2*16A	16/32A		
Max. input current	2*13A	13/26A		
Max. output power	11000W	12000W	13000W	15000W
Max. apparent power	12100VA	13200VA	14300VA	16500VA
Nominal output voltage	3W/N/PE 230/400Vac			
Max. output current	18.3A	20.0A	21.7A	25.0A
Nominal output frequency	50/60Hz			
Power factor range	0.8Leading ~ 0.8Lagging			
Safety level	Class I			
Ingress protection	IP66			
Operation ambient temperature	-25°C - +60°C			
Software version	DL 1.0			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-200092R1

Model	MOD 3000TL3-X2(Pro)	MOD 4000TL3-X2(Pro)	MOD 5000TL3-X2(Pro)	MOD 6000TL3-X2(Pro)	MOD 7000TL3-X2(Pro)	MOD 8000TL3-X2(Pro)
Max. DC voltage	1100V					
MPP voltage range	140-1000V					
Full-load voltage range	250-850V				300-850V	
No. of MPP trackers	2					
No. of PV strings per MPP trackers	1/1					
Max. input current per MPP trackers	20A/20A					
Max. short-circuit current per MPP trackers	25A/25A					
AC rated power	3kW	4kW	5kW	6kW	7kW	8kW
Max. AC apparent power	3.3kVA	4.4kVA	5.5kVA	6.6kVA	7.7kVA	8.8kVA
Nominal AC voltage	3W/N/PE,220V/380V; 230V/400V					
AC grid frequency	50/60 Hz					
Max. output current	5.0A	6.7A	8.3A	10.0A	11.7A	13.3A
Adjustable power factor	0.8Leading ...0.8Lagging					
Operating temperature range	-25°C ... +60°C (>45°C Derating)				-25°C ... +60°C (>40°C Derating)	
Protection degree	IP66					
Software Version	DL1.0					

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-200092R1

Model	MOD 9000TL3-X2(Pro)	MOD 10KTL3-X2(Pro)	MOD 11KTL3-X2(Pro)	MOD 12KTL3-X2(Pro)	MOD 13KTL3-X2(Pro)	MOD 15KTL3-X2(Pro)
Max. DC voltage	1100V					
MPP voltage range	140-1000V					
Full-load voltage range	350-850V		400-850V		500-850V	
No. of MPP trackers	2					
No. of PV strings per MPP trackers	1/1					
Max. input current per MPP trackers	20A/20A					
Max. short-circuit current per MPP trackers	25A/25A					
AC rated power	9kW	10kW	11kW	12kW	13kW	15kW
Max. AC apparent power	9.9kVA	11kVA	12.1kVA	13.2kVA	14.3kVA	16.5kVA
Nominal AC voltage	3W/N/PE,220V/380V; 230V/400V					
AC grid frequency	50/60 Hz					
Max. output current	15.0A	16.0A	18.3A	20.0A	21.7A	25.0A
Adjustable power factor	0.8Leading ...0.8Lagging					
Operating temperature range	-25°C ... +60°C (>40°C Derating)					
Protection degree	IP66					
Software Version	DL1.0					

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.